



Unit 30 | Fern Close | Pen-Y-Fan Ind Est | Oakdale | Gwent | NP11 3EH | UK  
Tel: +44 (0) 1495 236260 wales@nsf.org | www.nsf.org

# TEST REPORT

**Customer: C0710937**

"EBYK" Georgios Pefitselis S.A.  
Anghialos Thessaloniki  
57011 Gefyra Thessaloniki  
Greece

---

**Result** Limited testing was undertaken on this product in accordance with WRAS Material Guidance document, paragraph 83 (vitreous enamel). This product has satisfied the criteria set out in BS 6920: Part 1: 2014 "Specification" and thus is suitable for use with hot (up to 85°C) and cold water.

---

Customer Name	"EBYK" Georgios Pefitselis S.A.
Product	"EBYK" Georgios Pefitselis S.A. Enamel Coating
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00436943
Work Order Number	W0771182

---

**Thank you for having your product tested by NSF Wales Ltd.**

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

**Report Date** 01-DEC-2022

**Report Authorisation**

Michael Bustin - Materials Testing Manager



0626