

Approval Number 2212522
Test Report: J-00436943



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

13th December 2022

'EBYK' Georgios Peftitselis S.A.
Anghialos Thessaloniki,
57011 Gefyra Thessaloniki,
Greece

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS- FACTORY APPLIED PIPE & FITTINGS COATINGS.

5030

'EBYK' Georgios Peftitselis S.A. Enamel Coating'. Factory applied, blue coloured enamel coating.
Apply as per manufacturer's data sheet 'MS1555A' dated 12-10-18. Cure for 14 minutes@840°C.

For use with water up to 85°C.

This material is only approved for the curing conditions that appear on the approval. If the curing conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

APPROVAL NUMBER: 2212522

APPROVAL HOLDER: 'EBYK' GEORGIOS PEFTITSELIS S.A.

The Scheme reserves the right to review approval.

Approval 2212522 is valid between December 2022 and December 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', is written over a horizontal line.

Ian Hughes
WRAS Approvals Manager